

2022 Consumer Confidence Report

Hill Water Works

11131010

Introduction

Like any responsible public water system, our mission is to deliver the best-quality drinking water and reliable service at the lowest, appropriate cost. Aging infrastructure presents challenges to drinking water safety, and continuous improvement is needed to maintain the quality of life we desire for today and for the future.


In the next few years, due to the level of outstanding debt, we do not anticipate any major replacement projects without some significant outside funding becoming available. Most of the system is now 80 years old and a plan needs to be developed to continue replacing the aging water mains.

Potential investments along with on-going operation and maintenance costs are supported by the user rates which were changed March 1, 2019 due to the financial loss that took place in 2018. When considering the high value we place on water, it is truly a bargain to have water service that protects public health, fights fires, supports businesses and the economy, and provides us with the high-quality of life we enjoy.

What is a Consumer Confidence Report?

The Consumer Confidence Report (CCR) details the quality of your drinking water, where it comes from, and where you can get more information. This annual report documents all detected primary and secondary drinking water parameters, and compares them to their respective standards known as Maximum Contaminant Levels (MCLs).

NOW IT COMES WITH A LIST OF INGREDIENTS.



The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-

products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The US Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

What is the source of my drinking water?

Our water comes from two 40-foot deep gravel pack wells at the pump station off of Murray Hill Road. The water is treated for routine disinfection and pH control to prevent corrosion.

Why are contaminants in my water? Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Do I need to take special precautions? Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

Source Water Assessment Summary

DES prepared drinking water source assessment reports for all public water systems between 2000 and 2003 in an effort to assess the vulnerability of each of the state's public water supply sources. Included in the report is a map of each source water protection area, a list of potential and known contamination sources, and a summary of available protection options. The results of the assessment, prepared on 9/28/2001 and 9/30/2005 are noted below.

- Gravel pack well 1, 0 susceptibility factors were rated high, 4 susceptibility factors were rated medium and 8 susceptibility factors were rated low
- Gravel pack well 2, 0 susceptibility factors were rated high, 4 susceptibility factors were rated medium and 8 susceptibility factors were rated low

Note: This information is over 16-20 years old and includes information that was current at the time the report was completed. Therefore, some of the ratings might be different if updated to reflect current information. At the present time, DES has no plans to update this data.

The complete Assessment Report is available for review at the Hill Town Offices. For more information, call Laura DeFazio at 934-7100 or visit the DES Drinking Water Source Assessment website at <http://des.nh.gov/organization/divisions/water/dwgb/dwspp/dwsap.htm>.

How can I get involved?

For more information about your drinking water, please call Laura DeFazio of Pump Systems Inc at 934-7100. Although we do not have specific dates for public participation events, feel free to contact the Water Commissioners with any questions you may have. The Water Commissioners meet on the 3rd Wednesday each month at 7:00 PM in the Caroline Robie meeting room of the Hill Public Library.

Definitions:

Ambient Groundwater Quality Standard or AGQS: The maximum concentration levels for contaminants in groundwater that are established under RSA 485-C, the Groundwater Protection Act.

Action Level or AL: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Abbreviations

BDL: Below Detection Limit

mg/L: milligrams per Liter

NA: Not Applicable

ND: Not Detectable at testing limits

pCi/L: picoCurie per Liter

ppb: parts per billion

ppm: parts per million

RAA: Running Annual Average

TTHM: Total Trihalomethanes

UCMR: Unregulated Contaminant Monitoring Rule

ug/L: micrograms per Liter

Drinking Water Contaminants:

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water system is responsible for high quality drinking water, but can not control the variety of materials used in your plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing cold water from your tap for at least 30 seconds before using water for drinking or cooking. Do not use hot water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://water.epa.gov/drink/info/lead/index.cfm>

LEAD AND COPPER

Contaminant (Units)	Action Level	90 th percentile sample value	Date	# of sites above AL	Violation Yes/No	Likely Source of Contamination	Health Effects of Contaminant
Copper (ppm)	1.3	.326	10/8/20	0	No	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.
Lead (ppb)	15	11	10/8/20	1	No	Corrosion of household plumbing systems, erosion of natural deposits	(15 ppb in more than 5%) Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791). (above 15 ppb) Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

SECONDARY CONTAMINANTS

Secondary MCLs (SMCL)	Level Detected	Date	Treatment technique (if any)	AL (Action Level), SMCL or AGQS (Ambient groundwater quality standard)	Specific contaminant criteria and reason for monitoring
Chloride (ppm)	0		N/A	250	Wastewater, road salt, water softeners, corrosion
Fluoride (ppm)	0		N/A	2	<i>Add Health effects language from Env-Dw 806.11 or attach public notice to CCR</i>
Iron (ppm)	.085(well 2)	6/6/19	N/A	0.3	Geological
Manganese (ppm)	0		N/A	0.05	Geological
Nickel	0		N/A	N/A	Geological; electroplating, battery production, ceramics
PH (ppm)	6.11(well 2) 6.82(well 1)	6/6/19 12/22/20	N/A	6.5-8.5	Precipitation and geology
Sodium (ppm)	2.6(well 2) 11.5(well 1)	6/6/19 12/22/20	N/A	100-250	We are required to regularly sample for sodium
Sulfate (ppm)	4.9(well 20) 4.7(well 1)	6/6/19 12/22/20	N/A	250	Naturally occurring
Zinc (ppm)	0		N/A	5	Galvanized pipes

Resident
Hill NH 03243

Please Help Protect Drinking Water

Dear Homeowner, Resident, or Business Owner:

I would like to ask for your cooperation in helping to ensure safe drinking water for yourself and for the Hill Water Works water system. The Hill Water Works water system participates in a program at the N.H. Department of Environmental Services (DES) that requires the water supplier to implement a source protection program to prevent drinking water sources from becoming contaminated. Once a source becomes contaminated, it is very costly and sometimes impossible to correct. Therefore, I am writing to you because your property is located in the Source Water Protection Area (SWPA) for this water system as delineated by the DES. The SWPA is the area from which water – and any contaminants – are likely to flow to the water system's well or surface water source. Furthermore, even if your property is not served by this public water system, the water from the SWPA might flow to your well too.

You are probably already aware that certain activities on your property can affect the quality of groundwater. Most people who have septic systems are aware that their septic system discharges to the ground and thus to groundwater. Similarly, any gasoline, motor oil, paint, garden chemicals, lawn chemicals, or other household chemicals that are spilled, sprayed, spread, or dumped onto the ground can make their way into groundwater. Because your property is within the SWPA for a public water system, activities on your property that affect groundwater can also affect the public water supply. And if your property uses an on-site well, your own water supply can be affected.

Fortunately, you can minimize the likelihood of groundwater contamination by following a few simple guidelines. Please take time to review and follow the instructions on the enclosed pamphlet, and make sure all family members, residents, or employees are aware of them. By following these tips, you can help minimize the potential for contamination of groundwater, your drinking water supply, and the public drinking water supply.

We need your help to protect this valuable source of drinking water. The management and users of this public water supply appreciate your cooperation. If you have any questions about this letter, about the enclosed pamphlet, or about the protection of groundwater and drinking water, please contact me at 603-934-7100. You may also contact the Drinking Water and Groundwater Bureau at DES at 603-271-2513 for additional information.

Sincerely,

Laura DeFazio
Hill Water Works Water System

Enclosures